

<b>Water Testing Results - Banks Elementary School</b>			
<b>Action Level is 15 parts per billion (ppb)</b>			
<b>Fixture Location/Description</b>	<b>Fixture ID #</b>	<b>Test Date</b>	<b>Test Result</b>
Classroom 104	22400100-001DW22A	11/17/2022	NIU
Classroom 104	22400100-002CF22A	11/17/2022	1.19
Classroom 105	22400100-003DW22A	11/17/2022	1.86
Classroom 105	22400100-004CF22A	11/17/2022	1.67
Classroom 106	22400100-005DF22A	11/17/2022	1.39
Classroom 106	22400100-006DW22A	11/17/2022	0.736
Classroom 107	22400100-007CF22A	11/17/2022	1.57
Classroom 107	22400100-008DW22A	11/17/2022	0.526
Classroom 108	22400100-009CF22A	11/17/2022	5.64
Classroom 108	22400100-010DW22A	11/17/2022	0.757
Classroom 109	22400100-011CF22A	11/17/2022	0.671
Classroom 109	22400100-012DW22A	11/17/2022	1.62
Library office	22400100-013CF22A	11/17/2022	0.846
Room 113	22400100-014CF22A	11/17/2022	0.636
Classroom 110	22400100-015DW22A	11/17/2022	0.71
Classroom 110	22400100-016CF22A	11/17/2022	0.88
Classroom 111	22400100-017CF22A	11/17/2022	0.589
Classroom 111	22400100-018CF22A	11/17/2022	2.32
Classroom 112	22400100-019DW22A	11/17/2022	1.28
Classroom 112	22400100-020CF22A	11/17/2022	1.02
Classroom 101	22400100-021CF22A	11/17/2022	0.822
Classroom 101	22400100-022DW22A	11/17/2022	2.16
Classroom 102	22400100-023DW22A	11/17/2022	1.54
Classroom 102	22400100-024CF22A	11/17/2022	1.81
Classroom 103	22400100-025DW22A	11/17/2022	1.85
Classroom 103	22400100-026CF22A	11/17/2022	3.96
Restroom	22400100-027BF22A	11/17/2022	5.11
Boys bathroom	22400100-028BF22A	11/17/2022	1.49
Hallway drinking fountain	22400100-029DW22A	11/17/2022	<LOQ
Girls bathroom	22400100-030BF22A	11/17/2022	1.34

Restroom (second floor)	22400100-031BF22A	11/17/2022	2.47
Boys bathroom	22400100-032BF22A	11/17/2022	2.85
Girls bathroom	22400100-033BF22A	11/17/2022	2.09
Classroom 204	22400100-034DW22A	11/17/2022	0.409
Classroom 204	22400100-035CF22A	11/17/2022	1.57
Classroom 205	22400100-036DW22A	11/17/2022	0.904
Classroom 205	22400100-037CF22A	11/17/2022	0.267
Classroom 206	22400100-038DW22A	11/17/2022	4.43
Classroom 206	22400100-039DW22A	11/17/2022	0.747
Classroom 207	22400100-040CF22A	11/17/2022	0.384
Classroom 207	22400100-041DW22A	11/17/2022	1.57
Classroom 208	22400100-042DW22A	11/17/2022	1
Classroom 208	22400100-043CF22A	11/17/2022	1.03
Classroom 209	22400100-044DW22A	11/17/2022	NIU
Classroom 209	22400100-045CF22A	11/17/2022	4.19
Classroom 210	22400100-046DW22A	11/17/2022	0.892
Classroom 210	22400100-047CF22A	11/17/2022	3.23
Classroom 211	22400100-048DW22A	11/17/2022	3.39
Classroom 211	22400100-049CF22A	11/17/2022	1.72
Classroom 212	22400100-050CF22A	11/17/2022	0.888
Classroom 212	22400100-051CF22A	11/17/2022	0.869
Classroom 213	22400100-052CF22A	11/17/2022	1.72
Classroom 213	22400100-053DW22A	11/17/2022	2.35
Classroom 214	22400100-054DW22A	11/17/2022	1.04
Classroom 214	22400100-055CF22A	11/17/2022	0.998
Classroom 201	22400100-056DW22A	11/17/2022	0.826
Classroom 201	22400100-057CF22A	11/17/2022	0.502
Classroom 202	22400100-058CF22A	11/17/2022	1
Classroom 202	22400100-059DW22A	11/17/2022	0.92
Classroom 203	22400100-060CF22A	11/17/2022	0.461
Classroom 203	22400100-061DW22A	11/17/2022	0.648
Staff office--drinking fountain	22400100-062SF22A	11/17/2022	1.47
Staff office--sink	22400100-063SF22A	11/17/2022	0.675
Restroom	22400100-064BF22A	11/17/2022	1.65
Restroom	22400100-065BF22A	11/17/2022	2.68

Staff room	22400100-066SF22A	11/17/2022	1.7
Nurse's room	22400100-067NS22A	11/17/2022	0.989
Restroom	22400100-068BF22A	11/17/2022	8.62
Girls bathroom	22400100-069BF22A	11/17/2022	1.43
Drinking fountain	22400100-070DW22A	11/17/2022	0.614
Drinking fountain	22400100-071DW22A	11/17/2022	0.695
Boys bathroom	22400100-072BF22A	11/17/2022	3.63
Music room	22400100-073CF22A	11/17/2022	1.17
Music room	22400100-074DW22A	11/17/2022	5.82
Kitchen	22400100-075KF22A	11/17/2022	7.22
Kitchen	22400100-076KF22A	11/17/2022	2.94
Kitchen	22400100-077KF22A	11/17/2022	0.455
Kitchen	22400100-078KF22A	11/17/2022	2.15
Kitchen restroom	22400100-079BF22A	11/17/2022	0.712
Kitchen	22400100-080KF22A	11/17/2022	1.82
Kitchen	22400100-081KF22A	11/17/2022	1.51
Kitchen-dish sink	22400100-082KF22A	11/17/2022	2.32
Kitchen-ice machine	22400100-083IM22A	11/17/2022	1.38

**Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing**

< LOQ=Less Than Limit of Quantification (formerly ND-none detected)

NIU=Not in use or decommissioned