Columbia LABORATORIES
A Tentamus Company

12423 NE Whitaker Way
Portland, OR 97230
503-254-1794

**Report Number:** 22-014459/D002.R00
**Report Date:** 12/05/2022
**ORELAP#:** OR100028
**Purchase Order:**
**Project Name:** District Office/HS
**Project No:** Banks School District

## Cover Letter

Indy Safety
5010 NE Roselawn ST
Portland Oregon 97218
United States of America (USA)

Dear Elessar Connolly-Fairchild,

Enclosed please find Columbia Laboratories analytical report for samples received as order number 22-014459 on 11/18/2022 at 15:34. Should you have any questions about this report or any other matter, please do not hesitate to contact us. We are here to help you.

Thank you for allowing Columbia Laboratories to be of service to you, we appreciate your business.

Sincerely,

Derrick Tanner
General Manager



*Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Columbia Laboratories quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be retained for a maximum of 30 days from the receipt date unless prior arrangements have been made.*

Columbia LABORATORIES
A Tentamus Company

12423 NE Whitaker Way
Portland, OR 97230
503-254-1794

**Report Number:** 22-014459/D002.R00
**Report Date:** 12/05/2022
**ORELAP#:** OR100028
**Purchase Order:**
**Project Name:** District Office/HS
**Project No:** Banks School District

## Sample Results

**Sample:** 22400300-001 DW 22A | Collected: 11/18/22 05:00 | Temp: 16.6 °C | Matrix: Drinking Water
Lab ID: 22-014459-0001 | Received: 11/18/22 15:34 | Evidence of Cooling: N

**Method: EPA 200.8 in mg/l**

| Analyte | Result | Limit | Units | LOQ | Dil. | Batch | Start/Extract | Analyzed | Notes |
|---|---|---|---|---|---|---|---|---|---|
| Lead¥ | 2.7800 | 15.000 | µg/L | 0.2000 | 1.00 | 2210306 | | 11/30/22 16:17 | |

## Sample Results

**Sample:** 22400300-002 BF 22A | Collected: 11/18/22 05:01 | Temp: 16.6 °C | Matrix: Drinking Water
Lab ID: 22-014459-0002 | Received: 11/18/22 15:34 | Evidence of Cooling: N

**Method: EPA 200.8 in mg/l**

| Analyte | Result | Limit | Units | LOQ | Dil. | Batch | Start/Extract | Analyzed | Notes |
|---|---|---|---|---|---|---|---|---|---|
| Lead¥ | 5.9200 | 15.000 | µg/L | 0.2000 | 1.00 | 2210306 | | 11/30/22 16:19 | |

## Sample Results

**Sample:** 22400300-003 BF 22A | Collected: 11/18/22 05:02 | Temp: 16.6 °C | Matrix: Drinking Water
Lab ID: 22-014459-0003 | Received: 11/18/22 15:34 | Evidence of Cooling: N

**Method: EPA 200.8 in mg/l**

| Analyte | Result | Limit | Units | LOQ | Dil. | Batch | Start/Extract | Analyzed | Notes |
|---|---|---|---|---|---|---|---|---|---|
| Lead¥ | 1.4400 | 15.000 | µg/L | 0.2000 | 1.00 | 2210306 | | 11/30/22 16:20 | |

## Sample Results

**Sample:** 22400300-004 BF 22A | Collected: 11/18/22 05:03 | Temp: 16.6 °C | Matrix: Drinking Water
Lab ID: 22-014459-0004 | Received: 11/18/22 15:34 | Evidence of Cooling: N

**Method: EPA 200.8 in mg/l**

| Analyte | Result | Limit | Units | LOQ | Dil. | Batch | Start/Extract | Analyzed | Notes |
|---|---|---|---|---|---|---|---|---|---|
| Lead¥ | 1.7900 | 15.000 | µg/L | 0.2000 | 1.00 | 2210306 | | 11/30/22 16:22 | |

## Sample Results

**Sample:** 22400300-005 BF 22A | Collected: 11/18/22 05:04 | Temp: 16.6 °C | Matrix: Drinking Water
Lab ID: 22-014459-0005 | Received: 11/18/22 15:34 | Evidence of Cooling: N

**Method: EPA 200.8 in mg/l**

| Analyte | Result | Limit | Units | LOQ | Dil. | Batch | Start/Extract | Analyzed | Notes |
|---|---|---|---|---|---|---|---|---|---|
| Lead¥ | 3.2500 | 15.000 | µg/L | 0.2000 | 1.00 | 2210306 | | 11/30/22 16:23 | |



*Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Columbia Laboratories quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be retained for a maximum of 30 days from the receipt date unless prior arrangements have been made.*

Columbia LABORATORIES
A Tentamus Company

12423 NE Whitaker Way
Portland, OR 97230
503-254-1794

**Report Number:** 22-014459/D002.R00
**Report Date:** 12/05/2022
**ORELAP#:** OR100028
**Purchase Order:**
**Project Name:** District Office/HS
**Project No:** Banks School District

## Sample Results

**Sample:** 22400300-006 BF 22A | Collected: 11/18/22 05:07 | Temp: 16.6 °C | Matrix: Drinking Water
Lab ID: 22-014459-0006 | Received: 11/18/22 15:34 | Evidence of Cooling: N

**Method: EPA 200.8 in mg/l**

| Analyte | Result | Limit | Units | LOQ | Dil. | Batch | Start/Extract | Analyzed | Notes |
|---|---|---|---|---|---|---|---|---|---|
| Lead¥ | 4.4700 | 15.000 | µg/L | 0.2000 | 1.00 | 2210306 | | 11/30/22 16:24 | |

## Sample Results

**Sample:** 22400300-007 DW 22A | Collected: 11/18/22 05:10 | Temp: 16.6 °C | Matrix: Drinking Water
Lab ID: 22-014459-0007 | Received: 11/18/22 15:34 | Evidence of Cooling: N

**Method: EPA 200.8 in mg/l**

| Analyte | Result | Limit | Units | LOQ | Dil. | Batch | Start/Extract | Analyzed | Notes |
|---|---|---|---|---|---|---|---|---|---|
| Lead¥ | < LOQ | 15.000 | µg/L | 0.2000 | 1.00 | 2210306 | | 11/30/22 16:26 | |

## Sample Results

**Sample:** 22400300-008 BF 22A | Collected: 11/18/22 05:12 | Temp: 16.6 °C | Matrix: Drinking Water
Lab ID: 22-014459-0008 | Received: 11/18/22 15:34 | Evidence of Cooling: N

**Method: EPA 200.8 in mg/l**

| Analyte | Result | Limit | Units | LOQ | Dil. | Batch | Start/Extract | Analyzed | Notes |
|---|---|---|---|---|---|---|---|---|---|
| Lead¥ | 10.4000 | 15.000 | µg/L | 0.2000 | 1.00 | 2210306 | | 11/30/22 16:27 | |

## Sample Results

**Sample:** 22400300-009 BF 22A | Collected: 11/18/22 05:13 | Temp: 16.6 °C | Matrix: Drinking Water
Lab ID: 22-014459-0009 | Received: 11/18/22 15:34 | Evidence of Cooling: N

**Method: EPA 200.8 in mg/l**

| Analyte | Result | Limit | Units | LOQ | Dil. | Batch | Start/Extract | Analyzed | Notes |
|---|---|---|---|---|---|---|---|---|---|
| Lead¥ | 7.8500 | 15.000 | µg/L | 0.2000 | 1.00 | 2210306 | | 11/30/22 16:29 | |

## Sample Results

**Sample:** 22400300-010 BF 22A | Collected: 11/18/22 05:16 | Temp: 16.6 °C | Matrix: Drinking Water
Lab ID: 22-014459-0010 | Received: 11/18/22 15:34 | Evidence of Cooling: N

**Method: EPA 200.8 in mg/l**

| Analyte | Result | Limit | Units | LOQ | Dil. | Batch | Start/Extract | Analyzed | Notes |
|---|---|---|---|---|---|---|---|---|---|
| Lead¥ | 6.0600 | 15.000 | µg/L | 0.2000 | 1.00 | 2210306 | | 11/30/22 16:30 | |

***Units of Measure***

µg/L = Micrograms per liter = parts per billion (ppb)



*Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Columbia Laboratories quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be retained for a maximum of 30 days from the receipt date unless prior arrangements have been made.*

Columbia LABORATORIES
A Tentamus Company

12423 NE Whitaker Way
Portland, OR 97230
503-254-1794

**Report Number:** 22-014459/D002.R00
**Report Date:** 12/05/2022
**ORELAP#:** OR100028
**Purchase Order:**
**Project Name:** District Office/HS
**Project No:** Banks School District

***Abbreviations***
LOQ Limit of quantification

¥ = TNI accredited analyte.



*Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Columbia Laboratories quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be retained for a maximum of 30 days from the receipt date unless prior arrangements have been made.*

Columbia LABORATORIES
A Tentamus Company

12423 NE Whitaker Way
Portland, OR 97230
503-254-1794

**Report Number:** 22-014459/D002.R00
**Report Date:** 12/05/2022
**ORELAP#:** OR100028
**Purchase Order:**
**Project Name:** District Office/HS
**Project No:** Banks School District

INDYSAFE 22-014459

Indy Safety

Columbia LABORATORIES
A Tentamus Company

## Environmental Chain of Custody Record

Revision: 4.00 Document Control: CF001
Revised: 01/18/2021 Effective: 03/16/2021

Please inform us if you know or suspect that any part of your sample may contain hazardous materials or chemicals.

Company: INDY SAFETY
Contact: ELESSAR CONNOLLY-FARRELLO
Address: 5010 NE ROSELAWN
PORTLAND, OR 97218
Email: ELESSAR@INDYSAFETY.COM
Phone: (503) 481-2193 Fax: (___)
Billing (if different):

Analysis Requested
Preservative code: Verification of type used †

PO Number:
Project Number: BANKS SCHOOL DISTRICT
Project Name: DISTRICT OFFICE/
Custom Reporting: HIGH SCHOOL
☐ Report to State:
Turn-around time*: ☒ Standard ☐ Other, Due:
Rush: ☐4 day ☐3 day ☐2 day ☐ Next day
*Ask for availability. Samples received after 3pm are considered as received the following business day.
Sampled by: ELESSAR CONNOLLY-FARRELLO

| Lab ID | Field / Sample ID | Date/Time | Matrix †† | Comments |
|---|---|---|---|---|
| | 224003 00-001 DW 22A | 11-8-22 500 | DW | LOT 8417 |
| | 224003 00-002 BF 22A | 501 | | OA All |
| | 224003 00-003 BF 22A | 502 | | |
| | 224003 00-004 BF 22A | 503 | | |
| | 224003 00-005 BF 22A | 504 | | |
| | 224003 00-006 BF 22A | 505 | | |
| | 224003 00-007 DW 22A | 510 | | |
| | 224003 00-008 BF 22A | 512 | | |
| | 224003 00-009 BF 22A | 513 | | |
| | 224003 00-010 BF 22A | 514 | | |

| Relinquished By: | Date | Time | Received By: | Date | Time |
|---|---|---|---|---|---|
| E Connolly-Farrello | 11/8/22 | 8p | JMW | 11/8/22 | 15:34 |

Lab Use Only
☐ Shipped Via: ___ or ☐ Client drop off 16.6
Evidence of cooling: ☐ yes | ☐ No - Temp (°C): 16.6 16.6
If temp out, proceed?: ☐ yes | ☐ No
☐ Cash | ☐ Check | ☐ CC | ☐ Net:

Samples submitted to CL with testing requirements constitute an agreement for services in accordance with the current terms of service associated with this COC. By signing "Relinquished by" you are agreeing to these terms.

12423 NE Whitaker Way
Portland, OR 97230

P: (503) 254-1794 | Fax: (503) 254-1452
Info@columbialaboratories.com

Page 1 of 6
www.columbialaboratories.com



*Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Columbia Laboratories quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be retained for a maximum of 30 days from the receipt date unless prior arrangements have been made.*

Columbia LABORATORIES
A Tentamus Company

12423 NE Whitaker Way
Portland, OR 97230
503-254-1794

**Report Number:** 22-014459/D002.R00
**Report Date:** 12/05/2022
**ORELAP#:** OR100028
**Purchase Order:**
**Project Name:** District Office/HS
**Project No:** Banks School District

## Case Narrative

No Case Narrative notes to report.



*Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Columbia Laboratories quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be retained for a maximum of 30 days from the receipt date unless prior arrangements have been made.*