Radon Testing Results - Banks Elementary School
Action Level is 4.0 pCi/L

Site Name	Building Name	Room Description	Kit serial #	Date sampled	Type of test	Results
Banks Elementary School	Main building	Rm 104	507536	12/5/2022	Detector Kit	1.2
Banks Elementary School	Main building	Rm 105	507487	12/5/2022	Detector Kit	0.9
Banks Elementary School	Main building	Rm 106	507634	12/5/2022	Detector Kit	1.6
Banks Elementary School	Main building	Rm 107	507632	12/5/2022	Detector Kit	1.4
Banks Elementary School	Main building	Rm 108	509052	12/5/2022	Detector Kit	0.9
Banks Elementary School	Main building	Rm 108	507484	12/5/2022	Detector Kit	0.6
Banks Elementary School	Main building	Library N	507533	12/5/2022	Detector Kit	1
Banks Elementary School	Main building	Library S	507430	12/5/2022	Detector Kit	0.7
Banks Elementary School	Main building	Library Work Area	507550	12/5/2022	Detector Kit	0.8
Banks Elementary School	Main building	Library Office	507636	12/5/2022	Detector Kit	0.9
Banks Elementary School	Main building	Library Office (Dup)	507489	12/5/2022	Duplicate	1.2
Banks Elementary School	Main building	Library CC Rm	507519	12/5/2022	Detector Kit	0.7
Banks Elementary School	Main building	Rm 110	507639	12/5/2022	Detector Kit	Void
Banks Elementary School	Main building	Rm 111	506539	12/5/2022	Detector Kit	0.7
Banks Elementary School	Main building	Rm 112	507419	12/5/2022	Detector Kit	0.6
Banks Elementary School	Main building	Rm 101	507558	12/5/2022	Detector Kit	0.6
Banks Elementary School	Main building	Rm 102	507488	12/5/2022	Detector Kit	1.2
Banks Elementary School	Main building	Rm 103	507522	12/5/2022	Detector Kit	0.3
Banks Elementary School	Main building	Rm 152	507534	12/5/2022	Detector Kit	0.3
Banks Elementary School	Main building	Rm 153	507538	12/5/2022	Detector Kit	0.7
Banks Elementary School	Main building	Rm 151	507507	12/5/2022	Detector Kit	0.9
Banks Elementary School	Main building	Rm 151 (Dup)	507543	12/5/2022	Duplicate	0.7
Banks Elementary School	Main building	Rm 150	507548	12/5/2022	Detector Kit	0.8
Banks Elementary School	Main building	Office 156	507500	12/5/2022	Detector Kit	0.9
Banks Elementary School	Main building	Rm 157	509053	12/5/2022	Detector Kit	1.1
Banks Elementary School	Main building	Rm 158	507418	12/5/2022	Detector Kit	0.6
Banks Elementary School	Main building	Rm 159	507486	12/5/2022	Detector Kit	0.9
Banks Elementary School	Main building	Rm 155	507506	12/5/2022	Detector Kit	1
Banks Elementary School	Main building	Office Lobby	507514	12/5/2022	Detector Kit	0.7
Banks Elementary School	Main building	Rm 163	507510	12/5/2022	Detector Kit	0.4
Banks Elementary School	Main building	Rm 162	507498	12/5/2022	Detector Kit	0.6
Banks Elementary School	Main building	Rm 161	507638	12/5/2022	Detector Kit	0.5
Banks Elementary School	Main building	Rm 161 (Dup)	507490	12/5/2022	Duplicate	1

Banks Elementary School	Main building	Rm 154	507557	12/5/2022	Detector Kit	0.6
Banks Elementary School	Main building	Rm 177 music	507537	12/5/2022	Detector Kit	1.1
Banks Elementary School	Main building	Cafeteria 1	507497	12/5/2022	Detector Kit	Void
Banks Elementary School	Main building	Cafeteria 2	507511	12/5/2022	Detector Kit	0.7
Banks Elementary School	Gymnasium	PE Office	507524	12/5/2022	Detector Kit	0.8
Banks Elementary School	Gymnasium	Gym L	507481	12/5/2022	Detector Kit	0.3
Banks Elementary School	Gymnasium	Gym R	507526	12/5/2022	Detector Kit	0.7
Banks Elementary School	Main building	Cafeteria Office	507554	12/5/2022	Detector Kit	1
Banks Elementary School	Main building	Kitchen Office	507635	12/5/2022	Detector Kit	0.6
Banks Elementary School	Main building	Blank	517711	12/5/2022	Blank	-0.2
Banks Elementary School	Main building	Blank	517679	12/5/2022	Blank	0.2
Banks Elementary School	Main building	Office 101	507432	12/5/2022	Spike	45.3 (Spike)
Banks Elementary School	Main building	Office 102	507543	12/5/2022	Spike	40.4 (Spike)
Banks Elementary School	Main building	Rm 110	507492	12/5/2022	Retest	0
Banks Elementary School	Main building	Cafeteria 1	517821	12/5/2022	Retest	0.1